



To

Principal,
Scholars Rosary Senior Secondary School,
6th Km stone village Bohar, Sonapat Road , Rohtak

Memo No. 7403

Dated: 08/04/2025

Subject:- Issurance of building safety certificate for the building of Scholars Rosary Senior Secondary School , 6th Km stone , village Bohar , Sonapat Road, Rohtak.

Reference: Your office letter dated 20.02.2025

In this connection it is submitted that the site visual inspected by the undersigned & SDE incharge alongwith concerned JE of the above said school building. The Building has been constructed in the year 2006 as per statement of school authority. The columns has been tested by rebound hammer machine & reading comes out in permissible limit. Accordingly the above school building is seems to be structurally safe. The structural stability certificate is hereby issued for a period of one year from the date of issuance of this letter.

DA/Nil

Executive Engineer
Provincial Division No.2,
PW (B&R) Deptt., Rohtak

H:\PWD\Documents\p-II\Letter writer\Letter-c-Branch-3 R II. Docx

4503\001



For S.R. Education Society

Secretary

Principal,
Scholars Rosary Sr. Sec. School
6 K.M. Stone, Village Bohar,
Sonapat Road, Rohtak-124001
Aff. to CBSE (Code No. - 530759)